



Commonwealth Edison

One First National Plaza, Chicago, Illinois
Address Reply to: Post Office Box 767
Chicago, Illinois 60690

May 4, 1984

Mr. James G. Keppler
Regional Administrator
U.S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, IL 60137

Subject: Braidwood Station Units 1 and 2
Supplemental Response to IE Bulletin 83-06,
"Nonconforming Materials Supplied By Tubeline
Corp."
NRC Docket Nos. 50-456/457

- References (a): IE Bulletin No. 83-06 - R. C. DeYoung letter to
All OLs and CPs dated July 22, 1983 (NL-83-0034)
- (b): P. L. Barnes to J. G. Keppler letter dated
November 17, 1983 (NL-83-0550)
- (c): P. L. Barnes to J. G. Keppler letter dated
December 20, 1983 (NL-83-0701)

Dear Mr. Keppler:

Reference (a) requested that the Commonwealth Edison Company provide a written report regarding nonconforming materials supplied by Tube Line Corporation. References (b) and (c) provided that report.

In Reference (b) we identified four 3-inch 150 pound RF W/N Flanges supplied to Braidwood by Joliet Valve Co. through the Phillips Getschow Company. Two of these flanges were installed in the Boric Acid System and two were installed in the Containment Spray System. One of the Containment Spray System flanges had been replaced at the time of our Reference (b) submittal. We also committed to replace the other three flanges. These flanges have been replaced.

8405080173 840504
PDR ADOCK 05000456
Q PDR

IEI
1/0

To the best of my knowledge and belief the statements contained in the Attachment are true and correct. In some respects these statements are not based on my personal knowledge but upon information furnished by other Commonwealth Edison employees, consultants and contractors. Such information has been reviewed in accordance with Company practice and I believe it to be reliable.

Please address any questions that you or your staff may have concerning our response to IE Bulletin No. 83-06 to this office.

One (1) signed original with Attachment is being sent directly to the USNRC Document Control Desk in Washington, DC for reproduction and distribution as requested in the Bulletin.

Respectfully,

P. L. Barnes

P. L. Barnes
Nuclear Licensing Administrator

Attachments

cc: U.S. NRC, Document Control Desk ✓
Washington, DC 20555

RIII Inspectors - BW

SUBSCRIBED and SWORN to
before me this 4th day
of May, 1984

Rosalie A. Penta
Notary Public

7840N