



Telegram

TBA238(1510)(2-028357E135)PD 05/15/74 1510

ICS IPMBNGZ CSP

2057298316 TDBN DECATUR AL 35 05-15 0310P EDT

FON 4045264503 CB 9AM 446P-346

US ATOMIC ENERGY COMMISSION

REGION 2 DIRECTORATE OF REGULATORY OPERATIONS 230 PEACH TREE

ST NORTHWEST *230 Peach Tree*
Attn 30303

ATLANTA GA 30303

BFAO-743IT ON MAY 14 1974 AT APPROXIMATELY 2PM DURING A TORUS
ENTRY IT WAS OBSERVED THAT A NUMBER OF TORUS SPRAY HEADER TYPE
HANGERS WERE DISCONNECTED THE UNIT WAS IN A COLD SHUTDOWN CONDITION

H J GREEN BROWNS FERRY NUCLEAR PLANT

NNNN

SF-1201 (R5-69)

8305040798 740524
PDR ADDCK 05000259
S PDR