



Telegram

TBC053 (0920) (2-011147E134)PD 05/14/74 0919

ICS IPMBNGZ CSP

2057298316 TDBN ATHENS AL 40 05-14 0919A EDT

FON 4045264503

US ATOMIC ENERGY COMMISSION

REGION 2 DIRECTORATE OF REGULATORY OPERATIONS ~~230 PEACHTREE ST~~
NORTHWEST *230 Peachtree St.*
Atlanta Ga 30303

~~ATLANTA GA 30303~~

BFA0-7430T DURING ROUTINE SUVEILANCE TESTING OF EECW SYSTEM
ON 5-13 74 FCV-67-50 SUPPLY TO RBCCM WAS FOUND TO BE INOPERABLE
THE VALVE OPERATOR STRAINERS WERE CLEANED AND THE VALVE WAS
TESTED SATISFACTORILY THE UNIT WAS IN COLD SHUTDOWN CONDITION

H J GREEN/BROWNS FERRY NUCLEAR PLANT

NNNN

SF-1201 (R5-69)

8305050012 740523
PDR ADOCK 05000259
S PDR