



Telegram

TBA047(0916)(2-011026E134)PD 05/14/74 0916

ICS IPMBNGZ CSP

2057298316 TDBN ATHENS AL 61 05-14 0916A EDT

FON 4045264503

US ATOMIC ENERGY COMMISSION

REGION 2 DIRECTORATE OF REGULATORY OPERATIONS ~~230 PEACHTREE ST~~
NORTHWEST *230 Peachtree St.*
atla. Ga 30303

~~ATLANTA GA 30303~~

BFA0-7429T ON MAY 13 1974 AT 819AM WHILE CONDUCTING A ROUTINE
SURVEILLANCE TEST A SPRING WAS FOUND DISCONNECTED ON THE ARMATURE
OF ISOLATION RELAY. 10AK-983 THIS RELAY CONTROLS RHR SHUTDOWN
COOLING SYSTEM ISOLATION VALVE FCV74-47 AND RPV HEAD SPRAY ISOLATION
VALVE FCV74-77 THE RELAY WAS REPAIRED AND SATISFACTORILY TESTED
THE UNIT WAS IN A COLD SHUTDOWN CONDITION

H J GREEN/BROWNS FERRY NUCLEAR PLANT

NNNN

SF-1201 (R5-69)

8305050032 740523
PDR ADOCK 05000259
S PDR