



# Telegram

337P EDT MAY 13 74 AC132

DUPLICATE OF TELEPHONED TELEGRAM

AAB167(1527)(2-037902E133)PD 05/13/74 1527

ICS IPMMTZZ CSP

6092342900 RELAY TDMT MOORESTOWN NJ 05-13 0327P EDT

PMS 2-026204E133 2057298316 TDBN ATHENS AL 38 05-13 1253P EDT

US ATOMIC ENERGY COMMISSION, DUPLICATE REGION 2 DIRECTORATE OF  
REGULATORY OPERATIONS 230 PEACHTREE ST NORTHWEST WUX

ATLANTA GA 30303

BFAO-7428W AT APPROXIMATELY 2PM ON 5-12-74 A BROKEN YOKE WAS  
DISCOVERED ON FCV-74-58 LOOP 1 TORUS SPRAY VALVE THE UNIT WAS  
IN COLD SHUTDOWN CONDITION AN INVESTIGATION IS UNDERWAY TO DETERMINE  
THE CAUSE OF THE FAILURE

H J GREEN BROWNS FERRY NUCLEAR PLANT

NNNN

*May 14 38m  
of note mailed*

SF-1201 (R5-C9)

8305050042 740522  
PDR ADOCK 05000259  
S PDR

MGMATLT HSB

2-026239E133 05/13/74

ICS IPMBNGZ CSP

2057298316 MGM TDBN ATHENS AL 100 05-13 1253P EDT

ZIP 30303



Mailgram



US ATOMIC ENERGY COMMISSION

REGION 2 DIRECTORATE OF REGULATORY OPERATIONS 230 PEACHTREE ST  
NORTHWEST

ATLANTA GA 30303

BFA0-7428W AT APPROXIMATELY 2PM ON 5-12-74 A BROKEN YOKE WAS  
DISCOVERED ON FCV-74-58 LOOP 1 TORUS SPRAY VALVE THE UNIT WAS  
IN COLD SHUTDOWN CONDITION AN INVESTIGATION IS UNDERWAY TO DETERMINE  
THE CAUSE OF THE FAILURE

H J GREEN BROWNS FERRY NUCLEAR PLANT

12:53 EDT

MGMATLT HSB

*Handwritten:*  
50259