

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1)
Pilgrim Nuclear Power Station - Unit 1

DOCKET NUMBER (2)

0 5 0 0 0 2 9 3

PAGE (3)

1 OF 012

TITLE (4)

Fire Door Degradation

EVENT DATE (5)
MONTH DAY YEAR
0 4 0 5 8 4 8 4
LER NUMBER (6)
YEAR SEQUENTIAL NUMBER REVISION NUMBER
- 0 0 6 - 0 0 0
REPORT DATE (7)
MONTH DAY YEAR
5 0 4 8 4
OTHER FACILITIES INVOLVED (8)
FACILITY NAMES
DOCKET NUMBER(S)
0 5 0 0 0
0 5 0 0 0THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR 5. (Check one or more of the following) (11)
OPERATING MODE (9) N
POWER LEVEL (10) 0.00
20.402(b)
20.406(a)(1)(i)
20.406(a)(1)(ii)
20.406(a)(1)(iii)
20.406(a)(1)(iv)
20.406(a)(1)(v)
20.406(b)
30.36(a)(1)
30.36(a)(2)
30.73(a)(2)(i)
30.73(a)(2)(ii)
30.73(a)(2)(iii)
30.73(a)(2)(iv)
30.73(a)(2)(v)
30.73(a)(2)(vi)
30.73(a)(2)(vii)
30.73(a)(2)(viii)
30.73(a)(2)(ix)
73.71(b)
73.71(c)
OTHER (Specify in Abstract below and in Text, NRC Form 366A)

LICENSEE CONTACT FOR THIS LER (12)

NAME
William J. McCann - Senior Plant Engineer
TELEPHONE NUMBER
AREA CODE
6 1 7 7 1 4 1 6 1 - 7 1 9 1 0 1 0

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC										
X	N	G	I	D	R	W	2	2	1	N									

SUPPLEMENTAL REPORT EXPECTED (14)

X YES (If yes, complete EXPECTED SUBMISSION DATE)
NO
EXPECTED SUBMISSION DATE (15)
MONTH DAY YEAR
0 9 0 7 8 4

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

On 4/5/84, during a refueling outage, a detailed inspection was made of Technical Specification (T.S.) required fire doors. As a result of that inspection, 37 fire doors were found to be potentially non-functional due to holes in the door and frame, excessive spaces, or other damage. Fire patrols were established as a compensatory measure.

The plant may have been operated for some time prior to the December 10, 1983 shutdown with these doors in a degraded condition and without a fire patrol established as per T.S. 3.12.F.

8405080197 840504
PDR ADDCK 05000293
S PDR

DE22

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

U.S. NUCLEAR REGULATORY COMMISSION

APPROVED OMB NO. 3150-0104

EXPIRES 8/31/85

FACILITY NAME (1) Pilgrim Nuclear Power Station - Unit 1	DOCKET NUMBER (2) 0 5 0 0 0 2 9 3	LER NUMBER (6)			PAGE (3)		
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER			
		8 4	0 0 6	0 0	0 2	OF	0 2

TEXT (if more space is required, use additional NRC Form 366a) (17)

On 4/5/84, during a refueling outage, a detailed inspection was made of Technical Specification (T.S.) required fire doors. This inspection was initiated as a follow-up to an independent QA audit. A walkdown was initiated by the Station with new, more stringent acceptance criteria. As a result, 37 doors were determined to be potentially non-functional.

The Nuclear Engineering Department has been asked to evaluate the fire doors, some of which may be functional, and provide guidance for repair or replacement of non-functional fire doors. The cause and corrective action will be supplied in a supplemental report.

This event did not impact the health and safety of the public.

BOSTON EDISON COMPANY
800 BOYLSTON STREET
BOSTON, MASSACHUSETTS 02199

WILLIAM D. HARRINGTON
SENIOR VICE PRESIDENT
NUCLEAR

May 4, 1984
BECO #84-065

Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Docket Number 50-293
License DPR-35

Dear Sir:

The attached Licensee Event Report #84-006-00, "Fire Door Degradation," is hereby submitted in accordance with the requirements of 10CFR50.73.

If there are any questions on this subject, please do not hesitate to contact me.

Respectfully submitted,

W D Harrington
W. D. Harrington

WJM:caw

Enclosure: LER84-006-00

cc: Dr. Thomas E. Murley
Regional Administrator, Region 1
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

Standard BECO LER Distribution

IE22
1/1