

MGMATLT HSB

2-048860E127 05/07/74

ICS-IPMBNGZ CSP

2057298316 MGM TDBN ATHENS AL 100 05-07 0618P EDT

ZIP 30303



western union

Mailgram



US ATOMIC ENERGY COMMISSION

REGION 2 DIRECTORATE OF REGULATORY OPERATIONS 230 PEACHTREE ST
NORTHWEST

ATLANTA GA 30303

SUBJECT BFAO-7427T

PLANT OPERATIONS HAS BEEN ADVISED BY THE PLANT DESIGNER THAT
A NUMBER OF ONE INCH STAINLESS STEEL 600 PSIG INSTRUMENT VALVES
MAY HAVE BEEN WRONGLY APPLIED ON THE BROWNS FERRY UNITS INVESTIGATION
BEGUN TO DETERMINE NECESSARY ACTION UNIT ONE SHUT-DOWN IS IN
PROGRESS AEC INSPECTOR ON SITE

H J GREEN BROWNS FERRY NUCLEAR PLANT

18:18 EDT

MGMATLT HSB

MAY 8 9 27 AM '74

U.S.A.E.C.
REGION II
ATLANTA, GA.
REGULATORY OPERATIONS

8305050064 740612
PDR ADOCK 05000259
S PDR

Handwritten:
50259