

MGMATLT:HSB
2-048488E127 05/07/74
ICS IPMBNGZ CSP
2057298316 MGM TDBN ATHENS AL 100 05-07 0610P EDT
ZIP 30303



Mailgram



US ATOMIC ENERGY COMMISSION
REGION 2 DIRECTORATE OF REGULATORY OPERATIONS 230 PEACHTREE ST
NORTHWEST
ATLANTA GA 30303

SUBJECT BFA0-7426T
EVIDENCE INDICATES THAT A SAFETY RELEASE VALVE WAS SLOW RECEDING
ON TWO OCCASIONS FOLLOWING REACTOR TRIP AND ISOLATION MAY 5
AND 6 1974 RESPECTIVELY PLANT SHUT-DOWN IS IN PROGRESS AS INVESTIGATI
ON CONTINUES AEC INSPECTOR ON SITE
H J GREEN BROWNS FERRY NUCLEAR PLANT

18:10 EDT

MGMATLT HSB

MAY 8 9 27 AM '74

U.S.A.E.C.
REGULATORY OPERATIONS
REGION II
ATLANTA, GA.

8305050401 740515
PDR ADOCK 05000259
S PDR

Handwritten:
5259