



Telegram

TBB136(1307)(2-016456E072)PD 03/13/74 1307

CB 315

ICS IPMBNGZ CSP

2057298316 TDBN ATHENS AL 50 03-13 0107P EDT

FON 4045264503

US AUTOMIC ENERGY COMMISSION, FONE AND MAIL

REGION II DIRECTORETTE OF REGULATORY OPERATIONS 230 PEACH TREE  
ST NORTHWEST

ATLANTA GA 30303

SUBJECT BFA0-7416T ON MARCH 12 1974 THE HPCI TURBINE FAILED  
TO REACH RATED SPEED DURING A MANUAL INITIATION TEST THE TEST  
WAS BEING MADE TO RESOLVE SOME QUESTIONS CONCERNING OPERABILITY  
DURING THE LOAD REJECTION TEST CONDUCTED ON MARCH 14 1974 INVESTIGATI  
ON IS UNDERWAY TO DETERMINE THE CAUSE OF FAILURE

H J GREEN BROWNSFERRY NUCLEAR PLANT

NNNN

BF-1201 (R5-88)

COPY SENT TO:

PDR  
LPDR ✓  
NSIC  
TIC

8305060143 740912  
PDR ADOCK 05000259  
S PDR

*Handwritten:*  
50-259