

1973 JUN 4 AM 11 55

WUA122 ED148 1104 2-27121E100PD 06/04/73 1104

ICS IP BGGZ CSP

3096542241 IDB. CORDOVA IL 92 06-04 1104A ES.

PMS MR B GRIEL, DLR

REGIONAL DIRECTOR DIRECTORATE OF REGULATORY OPERATION US ATOMIC

ENERGY COMMISSION REGION 3 COMPLIANCE 700 ROOSEVELT RD

GLENN ELLEN IL

REF QUAD CITY NUCLEAR POWER STATION UNIT 1 DUCKT. NUMBER 20-224

LICENSE DPR-29 APPENDIX A SECTION 1.0A.4 AND 3.4.A WHILE CONDUCTING

ROUTINE MONTHLY SURVEILLANCE TESTING ON A UNIT 1 STAND-BY LIQUID

CONTROL SYSTEM THE 1B PUMP DID NOT MEET THE REQUIRED 35 GPM

FLOW RATE THIS ABNORMAL OCCURRENCE TOOK PLACE ON JUNE 4 1973

AT 0300AM THE FLOW RATE WAS MEASURED TO BE 14 GPM THE 1A PUMP

AND ALL OTHER SYSTEM COMPONENTS TESTED SATISFACTORY MAINTAINANCE

IS IN PROGRESS TO DETERMINE THE CAUSE OF THE FAILURE

N J KALIVIANAKIS QUAD CITY NUCLEAR POWER STATION CORDOVA IL

1102A CD.

MR

JUN 4 1973

8305120161 730612
PDR ADOCK 05000254
S PDR