

Tel

western union

Telex

western union

Telex

western union

VUA123 VED184 1332) 1-014738C343) PD 12/08/72 1329  
ICS IPMVEIG MVN  
LCZC 00074 TDVE CORDOVA ILL 107 12-08 1044A CST  
PMS MR ED JORDAN DLR DONT FONE US ATOMIC ENERGY COMM  
REGION 3 COMPLIANCE 799 ROOSEVELT ROAD  
GLEN ELLYN ILL

RE GUAD CITY NUCLEAR POWER STATION LICENSES DPR-29 AND 30  
APPENDIX A SECTION 1.0.A.2. 3.8.A.1 6.6.A.3

WHILE OPERATING BOTH UNITS AT 90 PER CENT POWER ON DEC. 8, 1972  
AT 0250 THE PLANT CHIMNEY MONITORING SYSTEM WAS DISCOVERED TO BE  
INOPERATABLE. THOUGH PRELIMINARY INDICATION IS THAT THE SAMPLE LINE  
IS FROZEN SOMEWHERE BETWEEN THE PUMB AND THE PROBE AND THE CHIMNEY.  
EFFORTS ARE IN PROGRESS TO CLEAR THE LINE WHILE MAINTAINING  
STEADY LOAD. ALL AIR EJECTORS OFF GAS MONITERS AND SAMPLE  
SYSTEMS ARE OPERABLE. OFF GAS RELEASE RATE IS LESS THAN 7,000  
UC/SEC BASED ON SAMPLE RESULTS.

1972 DEC 8 PM 1 19

B B STEVENSON CLARK CITY NUCLEAR STATION

101P CST

WU AGCY WHEA

DEC 8 1972

50-254-266  
Engineering

8305120174 730111  
PDR ADDCK 05000254  
S PDR