



Telegram

LD026

PDF

TDVE

CORDOVA ILL

DEC 2

100P CST

E JORDAN
REGION 3 COMPLIANCE
JS ATOMIC ENERGY COMMISSION
799 ROOSEVELT RD
GLEN ELLYN ILL 60137

REFERENCE QUAD-CITIES NUCLEAR POWER STATION DPR-30 APPENDIX A
SECTION 1.0.1.4. AND 6.6.A.3. AT 10:00PM ON DECEMBER 1ST 1972
WITH THE UNIT AT 90 PER CENT THERMAL POWER R.C.I.C. ISOLATION
VALVE 1301-17 FAILED TO CLOSE DURING THE MONTHLY SURVEILLANCE
TEST. VALVE 1301-16 WAS CLOSED AND THE HPCI SYSTEM WAS TESTED
AND FOUND TO BE OPERABLE.

ANN J KALIVIANAKIS

DEC 7 1972

50-254-365
Inquiry

WU 1201 (R 5-69)

8305120202 730105
PDR ADDCK 05000254
S PDR