



Telegram

317P EST OCT 21 72 DEA617 DE

DED092(1458)(1-016358C295)PD 10/21/72 1454

ICS IPMVEID MVN

ZCZC 141 D JW PDF TDVE CORDOVA ILL 21 1153A CDT

PMS MR ED JORDAN FONE AND MC

US ATOMIC ENERGY COMMISSION REGION 3 COMPLIANCE 799

ROOSEVELT RD GLEN ELLYN ILL

REXERENCE QUAD CITY NUCLEAR POWER STATION DPR 29

DPR 30 SECTION 1.0.A.4 AND 6.6.A.3 AND 6.6.B.3 AT

959PM WITH UNIT ONE REACTOR OPERATING IN THE "RUN" MODE

THE CORE SPRAY PUMP MOTOR AIR CIRCUIT BREAK (1422

ON BUS 14-1) FOR CORE SPRAY PUMP 1-1401B FAILED TO CLOSE ON

TEST THE CAUSE OF FAILURE WAS AN AUXILARY CONTACT IN THE

CIRCUIT BREAKER CUBICLES. THE 1-B CORE SPRAY PUMP WAS

TESTED AT 115AM ON 10/21/72 AT 951PM WITH UNIT TWO REACTOR "RUN"

MODE THIE HIGH PRSSURE COOLANT INJECTION SYSTEM FAILED TO

SF-1201 (RS-09)

1972 OCT 21 PM 3 19

312-858-2660



Telegram

OPERATE IN THE TEST MODE.THE REACTOR CORE ISOLATION COOLING SYSTEM
WAS TESTED SATISFACTORILY AT 1030PM ON 10/20/72. THE REACTOR WAS IN
COLD SHUT DOWN AT 830AM ON 10/21/72

B B STEPHENSON

29 30 1.0.A.4 6.6.A.3 6.6.B.3 959PM 1422 14-1 1-1401B

L1-B 115AM 10/21/72 951PM 1030PM 10/20/72 830AM 10/21/72

TELEGRAMS (OTHER THAN NIGHT ORDERS)
Is PHYSICAL DELIVERY requested? (YES-ENT. NO-ADVISE)
AGENT SECTION
Nbr. & name
Date dtd 10-23 Time dtd 10:05 H To AC By 87
To be mailed or filed mail
Attempts to deliver (Indicate DA or BY)

8305120229 721103
PDR ADOCK 05000254
S PDR

OCT 26 1972

SF-1201 (RS-09)

REGULATORY OPERATIONS, REGION III

Incident Notification By: Commonwealth Edison Co. - Docket No. 50-254
Docket No. 50-265

Transmittal Date : October 27, 1972

Distribution:

RO Chief, RT&OB

RO Chief, RCB

RO:HQ (4)

Licensing (4)

DR Central Files

U.S. ATOMIC ENERGY COMM.
DIVISION OF COMPLIANCE

1972 OCT 30 PM 12 30

RECEIVED