



Telegram

1973 MAR 30 PM 2: 35

VEE169(1531)(2-211094E089)PD 03/30/73 1531

ICS IPMBNGZ CSP

ZCZC 3096542241 TDBN CORDOVA IL 138 03-30 0331P EST

PMS MR GRIER, DLR

U S ATOMIC ENERGY COMMISSION REGION 3 COMPLIANCE 799 ROOSEVELT
RD

GLEN ELLYN IL

REFERENCE QUAD-CITIES NUCLEAR POWER STATION DOCKET 50-254 AND
50-265. DPR 29 AND 30, APPENDIX A, SECTION 1.0.A.3 AND 3.8.D.3
ON MARCH 29 1973 THE (A) FLOOR DRAIN SAMPLE TANK WAS BEING DISCHARGED
TO THE RIVER AT A RATE EQUIVALENT TO 5 PERCENT OF THE TECHNICAL
SPECIFICATION LIMIT. ALTHOUGH THE VALVE LINEUP HAD BEEN CHECKED
PRIOR TO THE DISCHARGE, THE SAMPLE TANK INLET VALVE WAS DISCOVERED
TO BE OPEN AND SOME WATER BEING PROCESSED TO THE (B) SAMPLE
TANK WAS GOING TO THE (A) TANK. THIS RESULTED IN A MINOR UNPLANNED
RELEASE SINCE TWO SAMPLES OF THE "MIXED TANK" WERE NOT OBTAINED

SF-1201 (R5-69)

4-2-73

PRIOR TO RELEASE. DISCHARGE TO THE RIVER WAS TERMINATED IMMEDIATELY.
SUBSEQUENT ANALYSIS OF THE MIXED (A) TANK INDICATED THAT FOR
THE 35 MINUTE RELEASE PERIOD THE RATE NEVER EXCEEDED 9 PERCENT
OF THE TECHNICAL SPECIFICATION LIMIT

COMMONWEALTH EDISON COMPANY QUAD-CITIES NUCLEAR POWER STATION
NICK KALIVANAKIS

TELEGRAMS (OTHER THAN MONEY ORDERS)

Is PHYSICAL DELIVERY requested? (Indicate AGENT, NO-ADDRESSEES)

AGENT SECTION

AGENT SECTION

Nbr. & Name

Nbr.

Date dtd

Time dtd

To

Fy

To be mailed or filed

Attempts to deliver (Indicate DA or BY)

00255P

8305120243 730406
PDR ADOCK 05000254
S PDR

SF-1201 (R5-69)