



Telegram

VEB236(1711)(2-02239384177)PD 04/27/73 1711

ICS IPMBNGZ CSP

3096542241 TDBN CORDOVA

PMS B. GRIER, REGION 3

799 ROOSEVELT RD

GLEN ELLYN IL 60137

REFERENCE QUAD CITY NEUCLUAR POWER STATION UNIT 1 DOCKET 50-254
DPR-29, APPENDIX A SECTION 1.0.A.2 AND 3.1 DURING ROUTINE CALIBRATION
OF THE LOW LEVEL SCRAM SENSORS ON APRIL 27, 1973 3 SWITCHES
WERE FOUND TO HAVE DRIFTED BEYOND THE SET POINT REQUIRED BY
THE LIMITING CONDITIONS FOR OPERATIONS LIS 1-263-57AB AND 1-263-58A
TRIP AT CALIBRATION TEST PRESSURES OF 67.8, 67.1 AND 68.8 INCH
H2O RESPECTIFULLY. THE PRESSURE EQUALIVANT TO THE LCO IS 66.8.
ALL SWITCHES WERE RECALIBRATED TO LESS THAN 62.8

N. KALIVIANKIS QUAD CITY NEUCULAR POWER STATION

APR 30 1973

6F-1201 (R5-69)

8305120270 730427
PDR ADOCK 05000254
S PDR

Handwritten: 50254



UNITED STATES
ATOMIC ENERGY COMMISSION
DIVISION OF COMPLIANCE
REGION III
799 ROOSEVELT ROAD
GLEN ELLYN, ILLINOIS 60137

TELEPHONE
(312) 858-2660

File

REGULATORY OPERATIONS, REGION III

A. RO Inspection Report No. _____

Transmittal Date : _____

Distribution:

RO Chief, RT&OB or RO Chief, RCB
RO:HQ (5)
DR Central Files
Regulatory Standards (3)
Licensing (13)

Distribution:

RO Chief, M&FFB
RO:HQ (4)
L:D/D for Fuel & Materials
DR Central Files

B. RO Inquiry Report No. _____

Transmittal Date : _____

Distribution:

RO Chief, RT&OB or RO Chief, RCB (2)
RO:HQ (5)
DR Central Files
Regulatory Standards (3)
Licensing (13)

Distribution:

RO Chief, M&FFB
RO:HQ
DR Central Files

C. Incident Notification From: Commonwealth Edison Company DPR-29
(Licensee & Docket No. (or License No.))

Transmittal Date : April 30, 1973

Distribution:

RO Chief, RT&OB or RO Chief, RCB
RO:HQ (4)
Licensing (4)
DR Central Files

Distribution:

RO Chief, M&FFB
RO:HQ (4)
L:D/D for Fuel & Materials
DR Central Files