



Telegram

1973 APR 24 AM 8:39

VE3043(0937)(2-125655E114)PD 04/24/73 0937

ICS IPMBNGZ CSP

3096542241 TDBN CORDOVA IL 82 04-24 0937A EST

PMS B GRIER, FONE

US ATOMIC COMMISSION REGION 3 COMPLIANCE 799 ROOSEVELT RD

GLEN ELLYN IL 60137

REFERENCE QUAD CITIES NUCLEAR POWER STATION DOCKET NUMBER 50-265

DPR-30 APPENDIX A SECTION 1.0.A.2 AND 3.2.A WHILE PERFORMING

ROUTINE SURVEILLANCE CALIBRATION OF LIS 2-263-57A THE SWITCH

WAS FOUND TO HAVE DRIFTED TO 118 INCH H2O. THIS SWITCH INITIATES

A LOW LOW LEVEL GROUP ONE ISOLATION AT A SET POINT OF GREATER

THAN 83 INCHES ABOVE THE CORE 83 INCHES IS EQUIVALENT TO A CALIBRATIO

N PRESSURE OF 115 INCH H2O. ALL OTHER SWITCHES IN THE ONE OF

TWO TWICE LOGIC WERE WITHIN SPECIFICATIONS

N J KALIVIANAKIS

8305120276 730427
PDR ADOCK 05000254
S PDR

SF-1201 (RS-89)

APR 27 1973