

western union

Telegram

844P EST SEP 25 72 DEB831

1972 SEP 25 PM 8 53

DE DEC111(1629)(1-023783C269)PD 09/25/72 1620

ICS IPMVEIE MVN

ZCZC 067 E PDF JD TDVE CORDOVA ILL (25)NFT

PMS ED JORDAN

312-858-2660

US ATOMIC ENERGY COMMISSION REGION 3 COMPLAINEE 799 ROOSEVELT
RD GLEN ELLYN ILL 60137

REFERENCE QUAD CITY NUCLEAR POWER STATION DPR-29 APPENDIX A SEC-
TION 1.9.A.2, 1.9.A.4, 3.7.4, 6.6.A.E AND 6.6.B.3:

INSPECTION OF THE 12TH SUPPRESSION CHAMBER TO DRY WELL VACUUM BREAK-

ERS ON SEPTEMBER 23RD 1972 AT 9AM REVEALED THAT 3 WERE OPENED
WITH THE REMOTE POSITIONS INDICATIONS SHOWING CLOSED. VALVE
NUMBER 1601-33B WAS OPENED 1/16 INCH, 1601-32 WAS OPENED
1/16TT

G099WND 1601-32D WAS OPEN 3/4 INCH. THE REACTOR

SF-1201 (R5-69)

mail

Copy sent PDR

by Region

western union

Telegram

IS SHUTDOWN AND THE VALVES ARE BEING MODIFIED TO CORRECT THE
MALFUNCTION

BEN STEPHENSON QUAD CITIES NUCLEAR POWER STATION CORDOVA ILL

TELEGRAMS (OTHER THAN MONEY ORDERS)

Is PHYSICAL DELIVERY requested? (YES-AGENT, NO-ADDRESSEE)

AGENT SECTION

ADDRESSEE SECTION

Nbr. & Name

Nbr.

Date dtd 9/26

Time dtd 123P

To

M77

By

Jo

To be mailed or filed

Attempts to deliver (Indicate DA or BY)

mail

OCT 2 1972

8305120492 721108
PDR ADOCK 05000254

SF-1201 (R)

S

PDR

REGULATORY OPERATIONS, REGION III

Subject: Incident Notification - Telegram dated September 25, 1972

Docket No. 50-254

Distribution:

RO Chief, RT&OB

RO Chief, RCB

RO:HQ (4)

Licensing (4)

DR Central Files

PDR

Local PDR

NSIC

DTIE

U.S. ATOMIC ENERGY COMM.
DIVISION OF COMPLIANCE

1972 OCT 4 PM 2 48

RECEIVED