



# Telegram

527P EST AUG 29 72 DEB636

SSH207 DE CCA209 (SF 242CC106209) PD WU TSDEPT MOLI 0607P EDT08/29/72

ZCZC 001 DG PD TDMS CORDOVA ILL 29 455P CDT

ED JORDAN US ATOMIC ENERGY COMM REGION 3 COMPLIANCE

799 ROOSEVELT RD GLENN ELLYN ILL 60137

1972 AUG 29 PM 5 31

312-858-2660

BT

REF: QUAD CITIES NUCLEAR POWER STATION DPR-30 APPENDIX A SECTIONS  
1.9.A.2, 1.9A.4, 3.7.4, 6.6.A.3 AND 6.6.B.3

AT 3:30AM ON AUGUST 24, 1972 WITH UNIT 2 REACTOR SHUT DOWN  
INSPECTION OF SUPPRESSION CHAMBER TO DRYWELL VACUUM BREAKERS  
REVEALED THAT SIX WERE OPEN WITH REMOTE CLOSED INDICATION.

2 1265

THE VALVES ARE BEING DISASSEMBLED TO DETERMINE POSSIBLE FAULTS  
AND VENDOR REPRESENTATIVES ARE TO ADVISE FOR POSSIBLE REMEDIES

F A PALMER QUAD CITIES NUCLEAR POWER STATION

CORDOVA ILL

SEP 5 1972

SF-1201 (RS-69)

8305120568 720927  
PDR ADOCK 05000265  
S PDR

50-265