



Telegram

VEC285(1909)(2-181703E030)PD 01/30/73 1909

1973 JAN 30 PM 12:12

ICS IPMBNGZ CSP

ZCZC 3096542241 TDBN CORDOVA IL 106 01-30 0709P EST

PMS B GRIER, FONE

REGION 3 COMPLIANCE UNITED STATES ATOMIC ENERGY COMMISSION 799

ROOSEVELT RD

GLEN ELLYN IL 60137

REFERENCE DOCKET QUAD CITIES NUCLEARPOWER STATION DPR-30 APPENDIX

A SECTIONS 1.0.A.2 AND 3.5.G.1 AT 4AM ON JANUARY 30 1973 WITH

THE REACTOR AT 2246 MWT THE PRESSURE IN THE DISCHARGE PIPING

OF THE UNIT 2 RHR SYSTEM DROPPED AND ALARMED IN THE CONTROL

ROOM UPON INVESTIGATION IT WAS DISCOVERED THAT THE CHECK VALVE

2-1001-C-1C ON THE 2C RHR PUMP DISCHARGE WAS LEAKING THROUGH

AND THE FILL SYSTEM COULD NOT MAINTAIN PRESSURE THE C RHR PUMP

WAS TAKEN OUT OF SERVICE AND MO 2-1001-1C SUCTION VALVE WAS

CLOSED AND THE PRESSURE RECOVERED. ALL OTHER SYSTEMS WERE PROVEN

SF-1201 (RS-69)

Handwritten notes:
dks
858-2660
312 9184
MC
Is PHYSICAL DEL
AGENT SECTION
NBI: & N
Date dtd 1/31
To be mailed or filed
Attempts to deliver (initials)

OPERABLE AS REQUIRED BY TECHNICAL SPECIFICATIONS 4.5.A.4

N J KALIVIANAKIS

U.S. ATOMIC ENERGY COMM.
DIVISION OF COMPLIANCE

1973 FEB 5 PM 3 15

RECEIVED

Handwritten:
50-254/260
inging

8305120574 730130
PDR ADOCK 05000265
S PDR

FEB 2 1973

SF-1201 (RS-69)