



# Telegram

1973 JAN 19 AM 10:51

VEC091(1149)(2-109928E019)PD 01/19/73 1149

ICS IPMBNGZ CSP

ZCZC 3096542241 TDBN CORDOVA IL 57 01-19 1149A EST

PMS B GRIER, FONE

US ATOMIC ENERGY COMMISSION REGENT 3 COMPLIANCE 799 ROOSEVELT RD

GLEN ELLYN ILL 60137

REFERENCE QUAD CITY NUCLEAR STATION UNIT 1 DOCK IT 50-254, DPR-29

APPENDIX A SECTION 1.0.A.2, 3.2.B DURING A ROUTINE CALIBRATION

OF THE ECCS REACTOR LOW PRESSURE PERMISSIVE PRESSURE SWITCHES,

P S 1-263-52B WAS FOUND TO ACTUATE AT 271 PSIG CONTRARY TO THE

TECH STEC LCO OF 300-350 PSIG. THE SWITCH WAS CALIBRATED TO NO-ADDRESSEE

325 PSIG.

NICK KALIVIANAKIS

JAN 22 1973

AGENT SECTION

Nbr. & Name

Date dtd

To be mailed or filed

Attempts to deliver (Indicate DA or BY)

ADDRESSEE SECTION

Nor.

To

By

512-858-2660

SF-1201 (RS-69)

8305120588 730125  
PDR ADOCK 05000254  
S PDR

50-254  
inquiry