



Commonwealth Edison Company

ONE FIRST NATIONAL PLAZA ★ CHICAGO, ILLINOIS

Address Reply to:

POST OFFICE BOX 767 ★ CHICAGO, ILLINOIS 60690

October 30, 1972



Mr. Angelo Giambusso
Deputy Director of Reactor Projects
Directorate of Licensing
U.S. Atomic Energy Commission
Washington, D.C. 20545

Subject: Quad-Cities Station Special Report No. 2

Dear Mr. Giambusso:

Attached is Quad-Cities Station Special Report No. 2. This report is submitted as the result of the incident of August 20, 1972, on Quad-Cities Unit 2 when a jet pump failed.

Inspection of the jet pumps on Unit 1 will be performed during the refueling outage, presently scheduled for the fall of 1973. As a result, additional surveillance requirements have been placed on Quad-Cities Unit 1 while the incident is being analyzed. Continuation of the increased surveillance is under review by the Commonwealth Edison Company at this time as a result of this report.

Modified Technical Specifications, as discussed in Section VII of this report, will be submitted shortly for the Quad-Cities Station.

One original and 39 copies are provided for your use.

Very truly yours,

L.D. Butterfield, Jr.
Nuclear Licensing Administrator

50-265
epw

rept in pocket

8305120600 721218
PDR ADOCK 05000254
S PDR

5972

COPY SENT REGION