



# Telegram

506P EST AUG 21 72 DEA550

SSQ023 DE MSA034 PDB 2 EXTRA CORDOVA ILL 21 427P CDE

BOYCE GRIER REGIONAL DIRECTOR

USAEC DIRECTORATE OF REGULATORY OPERATIONS REGION 7

799 ROOSEVELT RD GLEN ELLYN ILL

REFERENCE QUAD CITIES NUCLEAR POWER STATION DPR30 APPENDIX A SECTION  
1.0A.2, 3.6.G, AND 6.6.A.3

1972 AUG 21 PM 5 45

TELEPHONE NO. 312 888 2660

TELEPHONED TO BG

TIME DELIVERED 1259P

BY 22 TO BE med

AT 11PM ON AUGUST 20 1972 WITH THE UNIT TWO REACTOR OPERATING AT SIXTY PERCENT POWER A RECIRCULATION LOOP FLOW IN BALANCE APPROACHING FIFTEEN PERCENT WAS DETECTED. FURTHER INVESTIGATION REVEALED ABNORMAL FLOW INDICATION ON JET PUMP #17 AND - AND ORDERLY SHUT DOWN WAS STARTED AT 1245 AM ON AUG 21 1972. THE UNIT HAS BEEN PLACED IN THE OLD SHUT DOWN CONDITION WHILE FURTHER RECIRCULATION AND JET PUMP FLOW DATA IS BEING ACCUMULATED. CONCURRENTLY PLANS ARE BEING MADE TO REMOVE THE REACTOR VESSEL INTERNALS TO VISUALLY INSPECT THE JET PUMP

SF-1201 (R5-69)

S A PALMER QUAD CITIES NUCLEAR POWER STATION CORDOVA ILLINOIS

DPR30 1.0A.2 3.6.G 6.6.A.3 11PM 20 1972 #17 1245 AM 21 1972 .

8305120616 721218  
PDR ADOCK 05000254  
S PDR

AUG 28 1972

2 1227

SF-1201 (R5-69)

50-265