



# Telegram

1002A EST AUG 13 72 DEA878

SSC127 DE CCG004 (SF 225CC501004) PD WU TRUX IL MVN

1972 AUG 13 1055A EDT 08/13/72 50

ZCZC 006 WT PDB TDVE CHICAGO ILL AUG 12 341P CDT

E JORDAN REGION THREE COMPLAINEE US ATOMIC ENERGY COMMISSION

799 ROOSEVELT RD GLEN ELLYN ILL 60127

BT

REFERENCE QUAD CITIES NUCLEAR POWER STATIONS DPR-30 APPENDIX A  
SECTION 1. 9. A. 23.2.D.1 AND 6.6.A.3 DURING A MAINTENANCE OUTAGE ON  
UNIT 2 A MODIFICATION OF THE OFF GAS ISOLATION CIRCUITY FROM A  
RADIATION WAS COMPLETED IN THE PROCESS OF TESTING THE MODIFICATION  
CIRCUITY THE FIFTEEN MINUTE TIMER WAS FOUND TO BE INOPERABLE DUE TO  
A BAD MOTOR THE MOTOR WAS REPLACED WITH A NEW ONE AND TESTED OUT  
SATISFACTORILY

F A PALMER QUAD CITIES NUCLEAR POWER STATION CORDOVA ILL  
NNNN(1057A EDT)

2 1192

AUG 17 1972

TELEPHONED TO

TIME DELIVERED

TO BE

312-858 2660

J. Y. 8/14  
1025A  
med

8F-1201 (R5-69)

9305120643 720817  
PDR ADOCK 05000265  
S PDR

50-454/265