



Telegram

1972 DEC 30 AM 9: 35

VEB049(1032)(1-006028C365)PD 12/30/72 1031

ICS IPMVEIE MVN

ZCZC 00017 TDVE CORDOVA ILL 54 12 30 445P CST

PMS MR BOYCE GRIER

REGIONAL DIRECTOR OF US ATOMIC COMMISSION

DIRECTOR OF REGULATORY OPERATION & Name

REGION 3

799 ROOSEVELT ROAD

GLEYS ELYEN ILL

REFERENCE QUADCITY NUCLEAR POWER STATION DEOCET 50-254 DTR 29

APPENDIX A SECTION 1.0.A.2 AND 3.1 DURING ROUTINE CALIBRATION

ON DECEMBER 28, 1972 ECH OIL PRESSURE SWITCH WAS FOUND

TO TRIP AT LESS THAN 900 PSIG CONTRARY TO TECHNICAL SPECIFICATIONS.

THE SWITCH TRIPPED AT 890PSIG AND HAS BEEN RECALIBRATED

TO GREATER THAN 900PSIG

TELEGRAMS (OTHER THAN MONEY ORDERS)

Is PHYSICAL DELIVERY requested?

(YES-AGENT, NO-ADDRESSEE)

AGENT'S DELIVERY

Date dtd

Time dtd

To

By

To be mailed or filed

Attempts to deliver (Indicate DA or BY)

med 12/30

312-858-2660

JAN 2 1973

8F-1201 (RS-69)

N KALVIANAKIS

QUADCITY NUCLEAR POWER STATION

50-254

8305130318 730111
PDR ADOCK 05000254
S PDR

8F-1201 (RS-69)