

Telex

western union

Telex

western union

1972 DEC 21 AM 11 44

WU MVN ILL

WU122

CI19 1102) 1-009637C356) PD 12/21/72 1100

ICS IPMVEIA MVN

ZCZC 00103 1-041898C355 1922 00386)

PMS

TDVE CORDOVA ILL 51 12-20 414P CST

ED JORDAN DLY 1.50

DLR US ATOMIC ENERGY COMMISSION REGION 3 COMPLIANCE

799 ROOSEVELT RD

GLENELLYN ILL RTE WHEATON ILL

REFERENCE QUAD CITIES NUCLEAR POWER STATION DOCKET NUMBER

50-265 DPR30 APPENDIX A SECTION 1.0.A.2 AND 3.1 3 OF THE 4 EHC OIL

PRESSURE SWITCHES WERE FOUND TO BE SET AT LESS THEN 900 PSIG

CONTRARY TO THE TECHNICAL SPECIFICATIONS. ALL SWITCHES WERE

RE-CALIBRATED TO TRIP AT GREATER THAN 900 PSIG

N KALIVIANAXIS

8305130323 730111
PDR ADOCK 05000254
S PDR

rec'd 12-21-72

50-254265
cy sent to PDR by [signature]

Telex