



# Telegram

WATS  
LD036

TDVE CORDOVA ILLINOIS DECEMBER 22 1972 139P

B GRIER  
U S ATOMIC COMMISSION  
REGION 3 COMPLIANCE  
799 ROOSEVELT ROAD  
GLEN ELLYN ILLINOIS 60137

REFERENCE QUAD CITY NUCLEAR POWER STATION D/P29 AND 30  
APPENDIX A SECTION 1.0.A.2, 3.8.A.1, 3.4.C. DOCKETS 50-254 AND  
50-264 WITH BOTH UNITS OPERATING AND IMPROPER VALVE LINE-UP  
SYSTEM FOR A PERIOD OF ABOUT ONE HOUR LOAD WAS STEADY DURING  
THE PERIOD AND ALL OF GAS MONITORS WERE OPERABLE AND SHOWED  
NO CHANGE. SAMPLE FLOW WAS RESTORED AT 0830 DECEMBER 11 1972  
AND IS IRREGULATORY IN THE SOLUTION LEVEL IN THE UNIT 2

WU 1201 (R 5-69)

LD036 TDVE CORDOVA ILLINOIS DECEMBER 11 1972 139P (P2)

STAND-BY LIQUID CONTROL TANK HAS BEEN DISCUSSED WITH REGION 3  
COMPLIANCE INSPECTORS AT THE STATION THIS WEEK. A FURTHER  
REVIEW OF THIS INCIDENT WHICH OCCURRED DECEMBER 17 1972 INDICATES  
THAT THE MINIMUM TECH SPEC LIMIT OF 3470 GALLONS WAS APPARENTLY  
EXCEEDED BY ABOUT 25 GALLONS THE LEVEL INDICATING SYSTEM IS  
CONSIDERED TO BE DEFICIENT AND A REPORT WAS BEING PREPARED IN  
ACCORDANCE WITH TECH SPEC 6.6.C.1. THIS IS NOW REPORTED AS AN  
ABNORMAL OCCURANCE.

8305130354 730306  
PDR ADOCK 05000254  
S PDR

50-254/2105

WU 1201 (R 5-69)