

1972 DEC 11 PM 2 25

O  
WU AGCY WHEA

WU MVN ILL  
KXKKWUA160 ZC00102 TDVE CORDOVA ILL 12-11 1135A CST  
MRS ED JORDAN DLR  
COMPLIANCE 799 ROOSEVELT RD US ATOMIC ENERGY COMM  
REGION 3 GLEN ELLYN ILL

REFERENCE QUAD-CITIES NUCLEAR POWER STATION UNIT 1 LICENSE  
DPR-29 APPENDIX A SECTION 1.0.A.4, 3.5.2, 6.6.A.3 AT  
10:26AM ON 12/10/72 WITH THE REACTOR AT 90 PERCENT POWER A SMALL  
FIRE WAS DISCOVERED IN THE MOTOR OF THE 1B 4.H. R SERVICE  
WATER PUMP. THE OTHER 3 PUMPS WERE TESTED IMMEDIATELY AND  
FOUND TO BE OPERABLE  
KALIVIANKIS

140P AS

DEC 11 1972

50-254-365  
Enquiry