



Telegram

1972 DEC 24 PM 2:48

mc
CT

VEA127(1545)(1-012514C359)PD 12/24/72 1542

ICS IPMVEIG MVN

ZCZC 00191 TDVE CORDOVA ILL 80778 12-24 141P CST (YES-AGENT, NO-ADDRESS)

PMS B GRIER FONE AND MC IMMY

REGION 3 COMPLIANCE UNITED STATES ATOMIC ENERGY COMMISSION

799 ROOSEVELT RD

GLENELYN ILL 60137

TELEGRAMS (OTHER THAN MONEY ORDERS)
Is PHYSICAL DELIVERY required? (YES-AGENT, NO-ADDRESS)
AGENT SECTION
ADDRESSEE SECTION
No. 312-858-2660
Date dtd _____
To be mailed or filed _____
Attempts to deliver (Indicate DA or BY) _____

REFERENCE: QUAD CITIES NUCLEAR POWER STATION DPR 30 APPENDIX A
SECTION 1.0.A.5 3.7.D.1 AND 3.7.D.2 DOCKET NUMBER 50-265

AT 11:20 P.M. ON 12/24/72 WITH THE UNIT 2 REACTORS AT
1490 MEGAWATT THERMO, CLEANUP SYSTEM OUTBOARD ISOLATION VALVE
2-1201-5 FAILED TO CLOSE WHEN THE OPERATOR ATTEMPTED TO
CLOSE THE VALVE. WHEN THE VALVE WAS FOUND TO BE
INOPERABLE INBOARD ISOLATION VALVE 2-1201-2 WAS CLOSED TO COMPLY
WITH SECTION 3.7.D.2 WHILE REPAIRS WERE MADE ON

VALVE 2-1201-5

DEC 27 1972

SF-1201 (RS-69)

NICHOLAS KALIVIANAKIS

Rob. L. S.

50-265
inquiry

8305180246 720105
PDR ADDCK 05000265
S PDR

SF-1201 (RS-69)