



Telegram

VER201(1719)(1-014426C330)PD 11/25/72 1713-858-2660

ICS IPMVEIA MVN

ZCZC 00344 CORDOVA ILL 81 11-25/1144A

PMS MR B GRIER REGION 3, DLR DONT FONE

COMPLIANCE US ATOMIC ENERGY COMMISSION 799 ROOSEVELT RD

GLEN ELLYN ILL 60137

REFERENCE QUAD-CITIES NECULAT POWER STATION UNIT 1 LICENSE DPR-29
APPENDIX A SECTION 1.0.A.2, 3.2.A AND 6.6.A.3 WHILE CONDUCTING
ROUTINE SURVEILLANCE CALIBRATION ON THE UNIT 1 MAIN STEAM LINE FLOW
SWITCHES, TWO SWITCHES WERE FOUND TO HAVE DRIFTED BEYOND THE TECH
SPEC LIMIT. THE SET POINT EQUIVALENT TO 120 PERCENT FLOW IS 100
PSID DPIS 1-261-2C TRIP AT 104 PSID DPIS 1-261-2D TRIP AT 102 PSID.
BOTH SWITCHES HAVE BEEN RECALIBRATED

N J KALIVIANAKIS

SF-1201 (RS-69) NOV 30 1972

8305180296 721201
PDR ADOCK 05000265
S PDR