



Telegram

VEA403(1825)(1-0570 12A326)PD 11/21/72 1822

ICS IPMLEIA LAGE

ZCZC00062 TDVE CORDOVA ILL 90 11-21 12 P CST

PMS B GRIER REGION COMPLIANCE UNITED STATES ATOMIC ENERGY COMM

799 ROOSEVELT RD GLEN ELLYN ILL 60137

REFERENCE QUAD CITY NUCLEAR POWER STATION UNIT 2 LICENSE DPR-30
APPENDIX A SECTION 1.0.A.2N 3.1, 3.2.A AND 6.6.A.3 DURING THE
NORMAL QUARTERLY CALIBRATION OF THE CONVENSER LOW VACUUM AND MAIN
STEAM LINE LOW PRESSURE SWITCHES ON UNIT 2 4 SWITCHES WERE FOUND
TO HAVE DRIFTED TO TRIP SETTING WHICH EXCEED THE LEVELS SPECIFIED
IN THE TECHNICAL SPECIFICATION PS 2/503A TRIP AT 22.3 INCHES
HG PS 2/503D TRIP AT 22.4 INCHES HG PS2/261/30A TRIP AT 838 PSIG
PS2/261/30C TRIP AT 844 PSIG ALL SWITCHES HAVE BEEN RECALIBRATED
AND TESTED

NICK KALIVIANAKIS

NOV 24 1972

SF-1201 (R5-69)

8305180303 721201
PDR ADOCK 05000265
S PDR