

Duke Power Company
McGuire Nuclear Generation Department
12700 Hagers Ferry Road (MG01VP)
Huntersville, NC 28078-8985

T. C. McMEEKIN
Vice President
(704)875-4800
(704)875-4809 Fax



DUKE POWER

May 30, 1995

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Subject: McGuire Nuclear Station
Docket Nos.: 50-369 and 370
McGuire Unit 1 ASME Section XI Code ISI Plan Update

Dear Sirs:

On February 27, 1995 Duke Power Company updated the McGuire Unit 1 Inservice Inspection (ISI) Plan from the 1986 Edition of the ASME Section XI Code to the 1989 Edition. This Code update will take effect with the start of the second period of the second interval, which includes refueling outages 10 through 14. The First Period Inservice Inspection program was conducted to the 1986 Edition of Section XI, and included refueling outages 8 and 9.

During a comparative review for variations between the 1986 and 1989 Edition requirements, the Inservice Inspection requirements for snubbers was the only difference noted.

Request for Relief 94-11, submitted under a separate letter dated May 30, 1995 applies to the snubber inspections for McGuire Unit 1. This relief request is submitted because of the differences in examination requirements between the 1986 and 1989 Editions of ASME Section XI.

All requests for relief submitted for approval under the 1986 Section XI Code Edition are still applicable to the 1989 Code update.

Should there be any questions regarding this matter, please contact Dwin Caldwell at (704) 875-4328.

Very truly yours,

T. C. McMeekin
Vice President, McGuire Nuclear Station

9506060249 950530
PDR ADDCK 05000369
P PDR

A047
1/0

May 30, 1995

U.S. Nuclear Regulatory Commission

Page 2/3

xc: Mr. S. D. Ebnetter
Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta St., NW, Suite 2900
Atlanta, Ga. 30323

Mr. Victor Nerses
U.S. Nuclear Regulatory Commission
Office of Nuclear Reactor Regulation
Mail Stop 14H25
Washington, D.C. 20555

Mr. Robert E. Martin
U.S. Nuclear Regulatory Commission
Office of Nuclear Reactor Regulation
Washington, D.C. 20555

Mr. George F. Maxwell
NRC Resident Inspector
McGuire Nuclear Station

Dayne Brown, Chief
Division of Radiation Protection
P. O. Box 27687
Raleigh, N. C. 27611-7687

May 30, 1995

U.S. Nuclear Regulatory Commission

Page 3/3

bxc:

ELL/Topic	(EC050)
Jesse O. Barbour	(EC07J)
Jerry Goodman	(EC07J)
G. A. Copp	(EC050)
Z. L. Taylor	(CN01RC)
E. Burchfield	(ON01RC)
W. R. Cross	
Kay L. Crane	
Dwin E. Caldwell	
P. T. Vu	
John M. Washam	