

# Jersey Central Power & Light Company

MADISON AVENUE AT PUNCH BOWL ROAD • MORRISTOWN, N. J. 07960 • 539-6111

March 16, 1973


Mr. James P. O'Reilly, Director  
Directorate of Regulatory Operations, Region 1  
United States Atomic Energy Commission  
970 Broad Street  
Newark, New Jersey 07102

Dear Mr. O'Reilly:

Subject: Oyster Creek Station  
Docket No. 50-219  
Your February 23, 1973 Letter to R. H. Sims

In accordance with the subject letter, we have checked our facility and have determined that there are no Westinghouse circuit breakers with model numbers DB-25, DB-50, or DB-75 used in any of the engineered safeguards systems.

Very truly yours,



Donald A. Ross  
Manager, Nuclear Generating Stations

pk

*Requing  
50-219*