

**Omaha Public Power District**  
1623 Harney Omaha, Nebraska 68102  
402/536-4000

May 4, 1984  
LIC-84-132

Mr. James R. Miller, Chief  
U. S. Nuclear Regulatory Commission  
Office of Nuclear Reactor Regulation  
Division of Licensing  
Operating Reactors Branch No. 3  
Washington, D.C. 20555

Reference: Docket No. 50-285


Dear Mr. Miller:

**Adequacy of Station Electrical  
Distribution System Voltages**

Based upon a telephone conversation held between Mr. E. Tourigny and Mr. J. Enami of your staff; Mr. A. Udy of EG&G; and Mr. J. Fisicaro, Mr. R. Mehaffey, and Mr. M. Prawl of the District, it was determined that the District's December 19, 1983 letter concerning the subject requires additional information in order to clarify the District's intent.

The District's December 19, 1983 response to item 1, paragraph 2, contained a statement concerning operation of the condensate and feedwater pumps during accident conditions. It was not the intent of this response to imply that these pumps would be operating during accident conditions, simply that their operation could occur. The operation of these pumps is improbable, but not impossible. More correctly, the sentence should read: "Specifically, the condensate and feedwater pumps which when operating in the recirculation mode, as they would be if operated during accident conditions, require 70% and 63% of their motor horsepower, respectively." This should serve to clarify the District's intent and resolve the concern regarding this statement.

Sincerely,

  
W. C. Jones  
Division Manager  
Production Operations

WCJ/DJM:jmm

cc: LeBoeuf, Lamb, Leiby & MacRae  
1333 New Hampshire Avenue, N.W.  
Washington, D.C. 20036

Mr. E. G. Tourigny, Project Manager  
Mr. L. A. Yandell, Senior Resident  
Inspector

Employment with Equal Opportunity  
Male/Female

*Handwritten:* 1001  
110