



Telegram

1972 APR 12 PM

332P EST APR 12 72 DE4453

SSK017 DE CCB361 (SF 103CC228361)PD WU TSDEPT MOLI 0236P EST 04/12/72

ZCZC 001 DG PD TDMS CORDOVA ILL 12 115P CST

U S ATOMIC ENERGY COMM DUANE BOYD REG 3 COMPLIANCE

799 ROOSEVELT RD GLEN ELLYN ILL 60137

BT

REFERENCE QUAD CITY NUCLEAR POWER STATION UNIT ONE DPR-29

APPENDIX A SECTION 6.6A.3. DURING A START UP TEST ON THE UNIT ONE REACTOR CORE ISOLATION COOLING SYSTEM AT 430PM ON 4/11/72 THE SYSTEM WAS FOUND TO BE INOPERABLE. THE REACTOR WAS IN THE (START) MODE AND AT A PRESSURE OF 950 PSIG. THE HIGH PRESSURE COOLANT INJECTION SYSTEM WAS TESTED SATISFACTORILY AT 445PM ON 4/11/72. THIS ABNORMAL OCCURANCE IS REPORTED AS INCIDENT NUMBER 1-72-5

COMMONWEALTH EDISON CO QUAD CITY NUCLEAR POWER STATION

SF-1201 (R5-69) CORDOVA ILL B B STEPHENSON

DPR-29 6.6A.3 430PM 4/11/72 950 PSIG 445PM 4/11/72 1-72-5
NNNN(0236P EST)

8305190109 720419
PDR ADDCK 05000254
S PDR

APR 17 1972