



Commonwealth Edison  
Quad-Cities Generating Station  
Post Office Box 216  
Cordova, Illinois 61242  
Telephone 309/654-2241

NJK-74-258

Teletype: Region III, Attention: Mr. C. Peierabend

September 3, 1974

J. Keppler, Regional Director  
Directorate of Regulatory Operations  
Region III  
U. S. Atomic Energy Commission  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Reference: Quad-Cities Nuclear Power Station, Unit 2  
Docket No. 50-265, DPR-30  
Appendix A, Sections 1.0.A.4, 4.1.a, Table 4.1.1,  
6.6.B.1.a.

Dear Mr. Keppler:


The purpose of this letter is to provide you with notification of an Abnormal Occurrence as required by Technical Specification 6.6.B.1.a within 24 hours of the occurrence.

With Unit 2 reactor in the Cold Shutdown Condition at 4:30 AM on September 3, 1974, during monthly surveillance testing on MSIV closure, a half scram and annunciator alarm were not received when fuse 590-102F was pulled and valve AQ-2-203-1D was closed. The test was repeated three times at 10:00 AM and a half scram and alarm were received each time. Electrical Maintenance personnel are in the process of investigating circuitry.

This occurrence was discussed by telephone with Mr. Peierabend of your office on September 3, 1974. Further information will be provided by Abnormal Occurrence Report AO 50-265/74-23 which will be submitted within 10 days of the date of this occurrence.

Very truly yours,

COMMONWEALTH EDISON COMPANY  
QUAD-CITIES NUCLEAR POWER STATION

  
N. J. Kalivianakis  
Station Superintendent

NJK/LPG/rnb

cc: Directorate of Nuclear Energy  
J. S. Abel

SEP 3 1974

8305190146 740913  
PDR ADDCK 05000265  
S PDR

4/6 p