



Commonwealth Edison
Quad-Cities Generating Station
Post Office Box 616
Cordova, Illinois 61242
Telephone 309/854-2241

NJK-74-252

August 29, 1974

Teletype: Region III, Attention: Mr. C. Feiersabend

J. Keppler, Regional Director
Directorate of Regulatory Operations
Region III
U. S. Atomic Energy Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Reference: Quad-Cities Nuclear Power Station, Unit 2
Docket No. 50-265, DPR-30
Appendix A, Sections 1.0 & A.2.3.2.A, Table 3.2.1.

Dear Mr. Keppler:

The purpose of this letter is to provide you with notification of an Abnormal Occurrence as required by Technical Specification 6.6.B.1.a, within 24 hours of the occurrence.

While performing quarterly calibration of Main Steam High Flow Group I Isolation switches, DPIS-2-261-28 did not open at 109 psid (120 percent rated steam flow). The switch was re-calibrated, and functionally tested to open at 104 psid increasing three times. No prior failures have occurred with respect to this switch. The switch will be functionally tested weekly for one month, and will be examined during the next unit outage.

This occurrence was discussed by telephone with Mr. Jordana of your office on August 28, 1974. Further information will be provided by Abnormal Occurrence Report AQ 50-265/74-20 which will be submitted within 10 days of the date of this occurrence.

Very truly yours,

COMMONWEALTH EDISON COMPANY
QUAD-CITIES NUCLEAR POWER STATION

N. J. Kalivianakis
N. J. Kalivianakis
Station Superintendent

NJK/LFG/kr

cc: Directorate of Licensing
J. S. Abel

Handwritten: 50-265