



Commonwealth Edison
Quad-Cities Generating Station
Post Office Box 216
Cordova, Illinois 61242
Telephone 309/654-2241

NJK-74-195



Telecopy: Region III, Attention: Mr. C. Feierabend

August 2, 1974

J. Keppler, Regional Director
Directorate of Regulatory Operations
Region III
U. S. Atomic Energy Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Reference: Quad-Cities Nuclear Power Station, Unit 2,
Docket No. 50-265, DPR-30, Appendix A, Sections
1.0.A.2, 3.2.B, Table 3.2.2, 6.6.B.1.a and
AO-50-265/74-13.

Dear Mr. Keppler:

The purpose of this letter is to provide you with notification of an Abnormal Occurrence as required by Technical Specification 6.6.B.1.a within 24 hours of the occurrence.

While doing the special weekly surveillance test on LIS-2-263-72D as per our letter of July 11, 1974, the switch failed to actuate. The switch was lightly tapped and subsequently operated normally. Special weekly surveillance of this switch will continue until a new switch is received and installed. The switch has functioned normally on two previous special tests performed since July 11, 1974.

This occurrence was discussed by telephone with Mr. Jordan of your office on August 2, 1974. Further information will be provided by Abnormal Occurrence Report AO 50-265/74-19. This report is submitted in accordance with our representative agreement of receipt and installation of the new switch.

Very truly yours,

Commonwealth Edison Company
Quad-Cities Nuclear Power Station

[Signature]
N. J. Kalivianakis
Station Superintendent

NJK/LDR/SAA

cc: Directorate of Licensing
J. S. Abel

8305190194 761005
PDR ADOCK 95000265
PDR

[Handwritten: 50265]
8151
[Handwritten: M]
COPY SENT REGION