



Commonwealth Edison
Quad-Cities Generating Station
Post Office Box 216
Cordova, Illinois 61242
Telephone 309/654-2241

NJK-74-170

Telecopy: Region III, Attention: Mr. C. Feierabend

July 23, 1974



J. Keppler, Regional Director
Directorate of Regulatory Operations
Region III
U. S. Atomic Energy Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

50-254

Reference: Quad-Cities Nuclear Power Station, Unit 1
Docket No. 50-254, DPR-29, Appendix A
Sections 1.0.A.2, 3.2.B, and Table 3.2.2

Dear Mr. Keppler:

The purpose of this letter is to provide you with notification of an Abnormal Occurrence as required by Technical Specification 6.6.B.1.a within 24 hours of the occurrence.

On July 23, 1974, while performing routine quarterly instrument surveillance, the left hand switch of PS-1-263-528, tripped at 355 psig decreasing, thus violating Technical Specifications 3.2.B and Table 3.2.2. The instrument was inspected and no visible defects were found. The switch was re-calibrated to trip within the acceptable range.

This occurrence was discussed by telephone with Mr. Feierabend of your office on July 23, 1974. Further information will be provided by Abnormal Occurrence Report AO 50-254/74-25 which will be submitted within 10 days of the date of this occurrence.

Very truly yours,

COMMONWEALTH EDISON COMPANY
QUAD-CITIES NUCLEAR POWER STATION

[Signature]
N. J. Kalivianakis
Station Superintendent

NJK/CWS/jeh

cc: Directorate of Licensing
J. S. Abel

8305190210 740802
PDR ADOCK 05000254
S PDR

[Handwritten: 50-254]

796
COPY SENT REGION III