



Telegram

VEA294(1941)(1-044158C253)PD 09/10/74 1939

ICS IPMVEIA MVN

01389 TDVE MORRIS IL 66 09-10 142P CDT

PMS MR JAMES G KEPPLER

REGIONAL DIRECTER

DIRECTORATE OF REGULATORY OPERATIONS REGION 3

WUX US ATOMIC ENERGY COMMISSION

799 ROOSEVELT RD

GLENN ELLYN IL 60137

SUBJECT: DPR-19 DRESDEN NUCLEAR POWER STATION UNIT 2

THIS WILL CONFIRM A CONVERSATION WITH MR MAURA
OF YOUR OFFICE AT 0915 HRS THIS DATE CONCERNING FAILURE OF
"B" MAIN STEAM LINE HIGH RADIATION MONITOR AT 0300 THIS
MORNING. DURING WEEKLY SURVEILLANCE INITIATED ONE HALF
SCRAM AND ONE HALF ISOLATION UNTIL SATISFACTORY REPAIRS COMPLETED

1974 SEP 10 PM 7:02

TELEPHONE NO. 3-2183
DATE 9-11 TIME 1038A
BY B5
ATTENTION TO DELIVER. mail

8305190479 740919
PDR ADDCK 05000237
S PDR



Telegram

APPROXIMATELY 0345 THIS MORNING

B B STEPHENSON SUPERTINDENT
DRESDEN NUCLEAR POWER STATION
COMMONWEALTH EDISON CO
RR1 MORRIS IL 60450

NNNN

SEP 16 1974