

50-237



WU INFOMASTER 1-047151C253 09/10/74

TLX WU PRESS WSH C

208

TWX 7103280475 USAEC-HQS-GTWN

SPL228 WAB368(1941)(1-044158C253002)PD 09/10/74 1939

ICS IPMVEIA MVN

01390 TDVE MORRIS IL 66 09-10 142P CDT

PMS MR J F OLEARY DIRECTOR

DIRECTORATE OF LICENSING

WUX US ATOMIC ENERGY COMMISSION

WASHDC

SUBJECT: DPR-19 DRESDEN NUCLEAR POWER STATION UNIT 2

THIS WILL CONFIRM A CONVERSATION WITH MR MAURA
OF YOUR OFFICE AT 0915 HRS THIS DATE CONCERNING FAILURE OF
"B" MAIN STEAM LINE HIGH RADIATION MONITOR AT 0300 THIS
MORNING. DURING WEEKLY SURVEILLANCE INITIATED ONE HALF
SCRAM AND ONE HALF ISOLATION UNTIL SATISFACTORY REPAIRS COMPLETED
APPROXIMATELY 0345 THIS MORNING

B B STEPHENSON SUPERINTENDENT
DRESDEN NUCLEAR POWER STATION
COMMONWEALTH EDISON CO
RR1 MORRIS IL 60450

50-237
inquiry

2129 EDT

8305190481 740919
PDR ADOCK 05000237
S PDR

USAEC-HQS-GTWN

COPY SENT REGION TH