

WESTERN UNION INCOMING

BETH
008

USAEC HQS GTWN

1974 JUN 14 11 11 50

WU WSH

TLXA061

WAF042(0957)(2-009405E16S)PD 06/14/74 0957 U.S. ATOMIC ENERGY COMM. TWX UNIT

ICS IPMBNGZ CSP

3096542241 TDBV CORDOVA IL 89 06-14 0957A EDT

PMS JOHN F. OLEARY, DIRECTOR, DLR

DIRECTORATE OF LICENSE REGULATION US ATOMIC ENERGY COMMISSION
WASHINGTON DC 20545

REFERENCE QUAD CITIES NUCLEAR POWER STATION UNIT 2 DOCKET 50-265,
LPR-30, APPENDIX A SECTIONS 1.0.A.2, 3.2.B CABLE 3.2.2, AND
6.6.B

ON JUNE 13 WITH THE REACTOR IN THE COLD SHUT DOWN CONDITION,
SURVEILLANCE FUNCTIONAL TESTING WAS BEING PERFORMED. WHEN THE
TEST PRESSURE WAS APPLIED TO LIS-2-263-720 IT FAILED TO TRIP.
THE MERCURIO SWITCH WITHIN THE LEVEL SWITCH WAS NOT ACTUATING,
BUT UPON BEING LIGHTLY PRESSED IT STARTED FUNCTIONING NORMALLY.
IT WAS TESTED NUMEROUS TIMES WITH NO FAILURES. A NEW LIS WILL
BE OBTAINED TO REPLACE THE EXISTING UNIT.

N J KALIVIAVAKIS STATION SUPERINTENDENT
1100A EDT

USAEC HQS GTWN

WESTERN UNION INCOMING



5373

shape
50-265

8305190490 740711
PDR ADOCK 05000265
S PDR

COPY SENT REGION 3