



THE CLEVELAND ELECTRIC ILLUMINATING COMPANY

P.O. BOX 5000 - CLEVELAND, OHIO 44101 - TELEPHONE (216) 622-9800 - ILLUMINATING BLDG. - 55 PUBLIC SQUARE

Serving The Best Location in the Nation

MURRAY R. EDELMAN

VICE PRESIDENT
NUCLEAR

May 7, 1984
PY-CEI/NRR-0111 L

Mr. E. J. Youngblood
Licensing Branch No. 1
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Perry Nuclear Power Plant, Unit 1 and 2
Docket Nos. 50-440; 50-441
Final Response to Environmental
Qualification Audit Findings

Dear Mr. Youngblood:

This letter completes our response to the NRC/EQB Environmental Audit Findings for the Perry Nuclear Power Plant, Units 1 and 2. (See NRC EQB Audit Report to M. R. Edelman dated February 14, 1984, Item No. 4)

As previously stated at the audit and identified in Attachment A of our letter dated March 7, 1984 (PY-CEI/NRR-0093). CEI had conducted a review of it's EQ Program to identify all files that had test report summaries. Of the files identified, test reports and/or actual data were reviewed at three of the vendors facilities to assure proper qualification for use at PNPP. Commitments from the vendor were obtained which ensure that test reports will be maintained for the forty year life of PNPP. A record of these commitments have been added to the appropriate auditable file package.

If you have any questions please feel free to call.

Very truly yours,

Murray R. Edelman
Vice President
Nuclear Group

MRE:kay

cc: Jay Silberg, Esq.
John Stefano
Max Gildner

8405140116 840507
PDR ADDCK 05000440
PDR
A

A048
1/0