

PACIFIC GAS AND ELECTRIC COMPANY

PG&E

77 BEALE STREET • SAN FRANCISCO, CALIFORNIA 94106 • (415) 781-4211 • TWX 910-372-6587

May 8, 1984

J. O. SCHUYLER
VICE PRESIDENT
NUCLEAR POWER GENERATION

PGandE Letter No.: DCL-84-176

Mr. John B. Martin, Regional Administrator
U. S. Nuclear Regulatory Commission, Region V
1450 Maria Lane, Suite 210
Walnut Creek, CA 94596-5368

Re: Docket No. 50-275, OL-DPR-76
Docket No. 50-323
Diablo Canyon Units 1 and 2
IE Bulletin No. 84-02
Failures of GE Type HFA Relays in Class 1E Safety Systems

Dear Mr. Martin:

PGandE has reviewed IE Bulletin No. 84-02, "Failures of GE Type HFA Relays in Class 1E Safety Systems". Diablo Canyon Units 1 and 2 do not use nylon or Lexan-type GE HFA relays in safety-related systems, and the use of such relays is not contemplated.

Kindly acknowledge receipt of this material on the enclosed copy of this letter and return it in the enclosed addressed envelope.

Subscribed to in San Francisco, California this 8th day of May, 1984.

Respectfully submitted,

Pacific Gas and Electric Company

By

J. O. Schuyler
J. O. Schuyler
Vice President
Nuclear Power Generation

IE 11
1/0

Robert Ohlbach
Philip A. Crane, Jr.
Richard F. Locke
Attorneys for Pacific
Gas and Electric Company

By

Philip A. Crane, Jr.
Philip A. Crane, Jr.

Subscribed and sworn to before me
this 8th day of May, 1984

Nancy J. Lemaster
Nancy J. Lemaster, Notary Public in
and for the City and County of
San Francisco, State of California

SEAL

8405140261 840508
PDR ADDCK 05000275
Q PDR

cc: Document Control Desk
Service List

My commission expires April 14, 1986



NANCY J. LEMASTER
NOTARY PUBLIC - CALIFORNIA
CITY AND COUNTY OF
SAN FRANCISCO
My Commission Expires April 14, 1986