

MGMWSHT HSB
2-012900E110 04.00/74
ICS IPMBNGZ CSP
3096542241 MGM TDBN CORDOVA IL 100 04-20 0119P EDT
ZIP 20545

western union Mailgram



JOHN OLEARY, DIRECTOR DIRECTORATE OF LICENSING REGULATORY
US ATOMIC ENERGY COMMISSION
WASHINGTON DC 20545



REFERENCE QUAD CITIES NUCLEAR POWER STATION UNIT 1 DOCKET #50-254
DPR29 APPENDIX A SECTIONS 1.0.A.2, 3.2.A, CABLE 3.2.1, 6.6.B.1.A
ON APRIL 19 1974 WITH UNIT 1 IN COLD SHUT DOWN FOR THE CURRENT
REFUELING OUTAGE SERVALENCE TESTS REVEALED 9 OF 16 MPC1 HIGH
TEMPERATURE ISOLATION TEMPERATURE SWITCHES WITH SET POINTS EXCEEDING
THE LIMITING CONDITION FOR OPERATION OF LESS THAN OR EQUAL TO
200 DEGREES FAHRENHEIT ALL 16 TEMPERATURE SWITCHES WERE RECALIBRATED
TO 185 DEGREES FAHRENHEIT
N J KALIVIANAKIS

13:19 EDT

MGMWSHT HSB

8305200281 740429
PDR ADOCK 05000254
S PDR

3538

COPY SENT REGION *III*