

MGMWSHT HSB  
2-026813E085 03/26/74  
ICS IPMBNGZ CSP  
3096542241 MGM TDBN CORDOVA IL 145 03-26 0340P EDT  
ZIP 20545



Mailgram



50-265

JOHN OLEARY DIRECTORATE LICENSING  
US ATOMIC ENERGY COMMISSION  
WASHINGTON DC 20545



REFERENCE QUAD CITIES NUCLEAR POWER STATION UNIT TWO DOCKET  
NUMBER 50-265 DPR-30 APPENDIX A SECTION 1.0.A.2 AND 3.5.A.3  
AT APPROXIMATELY 1600 HOURS ON 3-25-74 WHILE PLACING SHUTDOWN  
COOLING MODE OF THE RHR SYSTEM IN OPERATION TO THE B RECIRC  
LOOP MOTOR OPERATED VALVE M02-10001-298 WAS FOUND TO HAVE DUAL  
POSITION INDICATION SUBSEQUENT CHECKS PROVED VALVE TO BE INOPERABLE  
BOTH MANUALLY AND AUTOMATICALLY. VALVE WAS TAKEN OUT OF SERVICE  
AND DISASSEMBLED. VALVE STEM WAS FOUND TO HAVE ABOUT A 1/8 INCH  
SOW OVER 24 INCH LENGTH OF THREADED PORTION THAT ENTERS THE  
MOTOR OPERATOR. UNIT WAS IN COLD SHUTDOWN MODE FOR SHORT OUTAGE  
AND WILL REMAIN IN COLD SHUTDOWN PER TECHNICAL SPECIFICATION  
3.5.F.2 UNTIL VALVE REPAIR IS COMPLETED. VALVE REPAIR BEING  
ATTEMPTED IS TO STRAIGHTEN MODE PORTION IN STATION SHOP.

N J KALIVIANAKIS COMMONWEALTH EDISON CO BOX 216 CORDOVA IL  
61242

15140 EST

MGMWSHT HSB

8305200682 740403  
PDR ADOCK 05000265  
S PDR

*Received  
50-265*

2600