

50-237

PAGE

BE 117 3  
008

1974 JUL 31 11 11

A0031

TWX 7108280475 USAEC HQS GTWN

S ATOM ENERGY COM  
T W X UNIT

SPLO31 WAB043(1017)(1-006656A212)PD 07/31/74 1014

ICS 1PWEIJ KVN

10023 IDVE MORRIS IL 80 07-31 820A CDT

PHS J F O'LEARY (JUX)

DIRECTOR DIRECTORATE OF LICENSING

U.S. ATOMIC ENERGY COMMISSION

WASHINGTON DC 20545

THIS WILL CONFIRM A CONVERSATION WITH F. MAURA OF YOUR OFFICE AT  
1500 HOURS THIS DATE JULY 30 CONCERNING CRACK IN LINE 2-350274-12  
INCHES-L WHICH IS THE FEED WATER HEATER DRAIN FROM 2D1 TO C1.  
REACTOR WAS IN COLD SHUT DOWN AT THE TIME AND REPAIRS ARE IN  
PROGRESS. AREA OF CRACK IS UNDER HOT WELL WHERE A PIPE SUPPORT  
IS WELDED TO THE BOTTOM OF THE LINES.

B B STEPHENSON

SUPERINTENDENT PRES. M POWER STATION

COMMONWEALTH EDISON CO.

RR 1 MORRIS ILLINOIS

1112 EDT

USAEC-HQS-GTWN

8305230640 740806  
PDR ADOCK 05000237  
S PDR

COPY SENT REGION

8025