

Western Union Telegram

1974 JUL 31 AM 9 35

CV
WU AGCY WHEA
YUA105 327A AS
ED303 10173 1-008656A2120023 PD 07/31/74 1014
ICS IPWVEIJ NVN
10024 TOME MORRIS IL 80 07-31 820A CDT
P/S JAMES G. KEPPLER WUXJ
799 ROOSEVELT RD REGIONAL DIRECTOR
DIRECTORATE OF REGULATORY OPERATIONS, REGION 3
U.S. ATOMIC ENERGY COMMISSION
SUPERINT. PRR-19 PRESIDENT NUCLEAR POWER STATION UNIT 2
GLENN ELLYN IL 60137
THIS WILL CONFIRM A CONVERSATION WITH F. MAURA OF YOUR OFFICE AT
1600 HOURS THIS DATE JULY 30 CONCERNING CRACK IN LINE 2-35087A-10
INCHES-L WHICH IS THE FEED WATER HEATER DRAIN FROM 2D1 TO C1.
REACTOR WAS IN COLD SHUT DOWN AT THE TIME AND REPAIRS ARE IN
PROGRESS. AREA OF CRACK IS UNDER HOT WELL WHERE A PIPE SUPPORT
IS WELDED TO THE BOTTOM OF THE LINES.
J. W. STEPHENSON

SUPERINTENDENT PRES. N POWER STATION
COMMONWEALTH EDISON CO.
RR 1 MORRIS ILLINOIS

NNNN

*Received
50 237*

8305230646 740806
PDR ADOCK 05000237
S PDR

JUL 31 1974

930A AS
WU AGCY WHEA