



Telegram

1974 JUL 25 PM 9:34

VEA330(2222)(1-048003C176)PD 06/25/74 2220

ICS IPMVEIA MVN

TELEGRAMS (OTHER THAN MONEY ORDERS)

01313 TDVE MORRIS IL 83 06-25 424P CDT

(YES-AGENT NO-ADDRESSEE)

PMS JAMES G KEPPLER

AGENT SECTION

REGIONAL DIRECTOR

Nbr. & Name

312-858-2660

Date dtd

6-26

Time dtd

10:30 A

To

FM

By

LM

DIRECTORATE OF REGULATORY OPERATIONS REGIONAL

WUX OF ATOMIC ENERGY COMMISSION

799 ROOSEVELT RD

GLENELLYN IL 60137

SUBJECT DPR-19 DRESDEN NUCLEAR POWER STATION UNIT 2

THIS WILL CONFIRM A CONVERSATION WITH F MAURA OF YOUR OFFICE

AT 1500 THIS DATE CONSIDERING DECREASE EFFICIENCY OF 2/3 (1

STAND BY GAS TREATMENT CHARCOAL BED FROM REQUIRED

EFFICIENCY OF 99 PERCENT TO 79 PERCENT. IT IS ASSUMED THAT

EFFICIENCY REDUCTION IS THE RESULT OF NORMAL USE.

305230739 740625
PDR ADDCK 05000237
PDR



Telegram

03V12332

1974 JUN 25 PM 5:34

AO 4 MT 9 JUL 1974

WORK ORDER IS SUBMITTED TO CHANGE CHARCOAL BED ON A TRAIN ANSWER SUR
VEYILLANCE WAS INITIATED ON T2/3 B TRAIN B TRAIN CHARCOAL TESTED AT
99 PERCENT EFFICIENT

B B STEPHENSON SUPT
DRESDEN NUCLEAR POWER STATION
COMMONWEALTH EDISON CO
R R 1
MORRIS IL 60450

NNNN

JUN 27 1974