



Telegram

VEC226(1649)(1-036772C163)PD 06/12/74 1649

1974 JUN 12 PM 3:52

ICS IPMVEIB MVN

02105 TDVE MORRIS ILL 104 06-12 210P CDT

312-858-2660

PMS MR JAMES G KEPPLER -- REGIONAL DIRECTOR DIRECTORATE OF REGULATORY
OPERATIONS REGION E US ATOMIC ENERGY COM 799 ROOSEVELT RD WUX
GLEN ELLYN ILL 60137

SUBJECT: DPR-19 DRESDEN NUCLEAR POWER STATION UNIT 2.

THIS WILL CONFIRM A CONVERSATION WITH F. MAURA OF YOUR OFFICE AT
1330 HOURS THIS DATE CONCERNING DRIFT OF REACTOR PROTECTION HIGH
PRESSURE SWITCH TWO 1066 PSI WHICH IS IN EXCESS OF TECHNICAL
SPECIFICATION LIMITS OF 1060 AND THE DRIFT OF ISOLATION
CONDENSER ISOLATION INITIATING SWITCH TWO 1075 WHICH IS IN
EXCESS OF TECHNICAL SPECIFICATION LIMITS OF 1070 PSI. BOTH
SWITCH DRIFT PROBLEMS WERE DISCOVERED DURING ROUTINE
SURVEILLANCE AND WERE IMMEDIATELY RESET TO THEIR PROPER VALUES.
REACTOR WAS SHUT DOWN AT THE TIME. SWITCHES WERE NOT PRECONDITIONED

Handled
50237

6305240036 740619
PDR ADDCA D5000237
PDR



Telegram

B B STEPHENSON SUPERINTENDENT
DRESDEN NUCLEAR POWER STATION
COMMONWEALTH EDISON COMPANY
ROUTE 1
MORRIS ILL 60450

NNNN

TELEGRAMS (OTHER THAN MONEY ORDERS)
IS PHYSICAL DELIVERY requested? (YES-AGENT, NO-ADDRESSEE)
AGENT SECTION ADDRESS SECTION
Nbr. & Name Nbr.
Date dtd Time dtd To By
To be mailed or filed
Attempts to deliver

JUN 8 1974

1005A
6/15 da 815A
W C W U 6/13