

June 13 100 W 4 1055 AM



Telegram

VEC258(1823)(1-042118C163)PD 06/12/74 1823

1974 JUN 12 PM 5:44

ICS IPMVEIH MVN

08277 TDVE MORRIS IL 112 06-12 200P CDT

PMS JAMES G KEPPLER REGIONAL DIRECTOR WUX DIRECTORATE OF  
REGULATORY OPERATIONS REGION 3 US ATOMIC ENERGY COMMISSION

799 ROOSEVELT ROAD

GLENN ELLYN ILL 60137

SUBJECT DPR-25 DRESDEN NUCLEAR POWER STATION UNIT 3 THIS  
WILL CONFIRM A CONVERSATION WITH F RAURA OF YOUR OFFICE

AT 1300 HOURS THIS DATE CONCERNING THE DISCOVERY DURING ROUTINE  
SURVEILLANCE TESTING OF 2 REACTOR HIGH PRESSURE SCRAM SWITCHES

(PS-3-263-55A & C) WITH SET POINTS ABOVE THE 1060 PSIG VALVE

ALLOWED BY LIMITING SAFETY SYSTEM SETTING 2.2.A THE SWITCHES

WERE FOUND TO OPERATE AT 1064 PSIG AND 1066 PSIG RESPECTIVELY

AND WERE IMMEDIATELY RESET TO 1048 PSIG AND 1044 PSIG ADDITIONAL

DETAILS ARE FORTHCOMING IN THE FORM OF A 10-DAY LETTER IN

8305240035 740612  
PDR ADDCK 05000237  
PDR



# Telegram

ACCORDANCE WITH SECTION 6.6.B.1.A OF THE TECHNICAL SPECIFICATIONS.

B B STEPHENSON SUPERINTENDENT DRESDEN NUCLEAR POWER STATION  
COMMONWELATH EDISON COPY RURAL ROUTE 1 MORRIS ILL 60450

NNNN

## TELEGRAMS (OTHER THAN MONEY ORDERS)

Is PHYSICAL DELIVERY requested? \_\_\_\_\_ (YES-AGENT, NO-ADDRESSEE)

AGENT SECTION

ADDRESSEE SECTION

Nbr. & Name \_\_\_\_\_

Nbr. 312-858-2660

Date dld \_\_\_\_\_

Time dld \_\_\_\_\_

To \_\_\_\_\_

By \_\_\_\_\_

To be mailed or filed \_\_\_\_\_

Attempts to deliver (Indicate OA or E)

415 dan 8/5A

WCU  
1055A

6/13